



Typical Fire Safety Measures Classes 2 - 9 Buildings

Basic BCA rules for buildings less than 25m high
Sprinklers & emergency warning systems required if height exceeds 25m